



Addendum No. 1

REQUEST FOR PROPOSALS ADM-22-01

Rural Septage Disposal Feasibility Study – Phase 1

The addendum is being issued prior to provide further information, make changes to, or to clarify the Request for Proposal Documents and is to be read, interpreted and coordinated with all other parts of the Request for Proposal Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. This addendum shall form part of the contract documents.

Question #1: *After reading through the RFP posted to the BC Bid website and scanning through the available postings under the Regional District of Fraser - Fort George I have been unable to find any documentation with site maps indicating where the community sewer systems are located. We feel that this information would be quite useful in determining where and what we would propose to remedy the Rural Septage Disposal issue.*

Answer #1: Attached is a map of community lagoon sewer systems in the area of interest for the study. Two of these systems are operated by the City of Prince George. The other 5 are operated by the Regional District of Fraser-Fort George. The Shelley Lagoon system, operated by the City of Prince George, is the only facility that currently accepts residential septage waste from rural residents. The other facilities are designed to handle the capacity of the residences they serve and have limited options for expansion to handle increased volumes. Additional information about these community sewer systems can be found at <https://www.rdffg.bc.ca/services/environment/wastewater-systems/overview-17>

Date: April 4, 2022

Addendum No. 1 Received.

Signature of Bidder

Name of Bidder

Inquiries relating to this RFP may be directed to:

Jim Martin
Chief Administrative Officer
jmartin@rdffg.bc.ca

Deadline for question submissions is 5:00 p.m. (local time) April 27th, 2022.

