



**REGIONAL DISTRICT
of Fraser-Fort George**

**EMERGENCY RESPONSE AND
CONTINGENCY PLAN FOR:**

**BEAR LAKE
SMALL WATERWORKS SYSTEM**

Update: November 2024

INTRODUCTION

The *Drinking Water Protection Act* requires a water supplier to monitor and protect its drinking water. An emergency response and contingency plan (ERCP) is a written document that spells out a water system's plan of action for responding to potential emergencies, disasters or abnormal operational circumstances. This plan is to provide guidelines that will minimize disruption of normal customer services and protect public health and safety if an incident should occur.

Each ERCP must include the following information:

1. The names and contact information of:
 - a. the management personnel for the water supply system;
 - b. the drinking water officer, medical health officer and public health inspector;
and,
 - c. other agencies and officials specified by the drinking water officer.
2. The persons referred to in paragraph (a) to be contacted in each type of emergency or abnormal operational circumstance.
3. The steps to follow in the event of an emergency or abnormal operational circumstance.
4. Protocols to follow respecting public notice if an immediate reporting standard cannot be met.

This specific ERCP was developed by the Regional District of Fraser-Fort George (RDFFG) for the Bear Lake Small Waterworks System. Within this plan specific community and RDFFG staff members are identified and assigned guideline procedures and appointed responsibilities. In the case of an incident, it is vital that these identified individuals be familiar with the scope of ERCP and their appointed responsibilities. This is to ensure that if an incident should occur, the safety of the public served by this water system is guaranteed and service disruption is minimal.

Emergency Response and Contingency Plan for The Bear Lake Small Waterworks System



TABLE OF CONTENTS

EMERGENCY RESONSE PLAN - ACTION LIST 5

- Distribution Water Main Failure 5
- Power Failure 5
- Complete Pump Failure at Pump House 6
- Contamination of Water..... 6
- Fire (Forest fire in water distribution area, or fire fighting with system water)... 7
- Loss of Source (Water Supply) 7
- Earthquake Loss or Structural Damage to Reservoir 8

APPENDIX A - EMERGENCY RESPONSE PLAN – RESPONSIBILITY PLAN ... 9

- Maintenance Contractor 9
- Designated RDFFG Staff (EOCP Certified) Contact 9
- Designated Bear Lake Community Commission Contact..... 10

APPENDIX B - EMERGENCY RESPONSE PLAN – CONTACT LIST 11

- RDFFG Personnel Contact Numbers 11
- Bear Lake Contact Numbers 11
- Government Agencies 12
- Public Services..... 12
- Media Contact Numbers..... 13
- Water Supply Services Contact Numbers 13
- Repair and Services Contact Numbers 14

APPENDIX C - MEDIA RELEASES – PREPARED PUBLIC SERVICE
ANNOUNCEMENTS 15

APPENDIX D - SIGNAGE – PREPARED SIGNAGE FOR POSTING..... 17

APPENDIX E - PHONE TREE – PREPARED WATER SYSTEM USER
SERVICE ANNOUNCEMENTS..... 26

APPENDIX F - WATER SYSTEM DRAWING 31

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

SITUATION – TYPE OF EMERGENCY	RESPONSE	CONTACTS
<p style="text-align: center;">Distribution Water Main Failure</p>	<p>See Appendix A for additional assigned responsibilities.</p> <ul style="list-style-type: none"> ◆ SCADA alarm system, Bear Lake maintenance contractor, or after-hours service to contact Regional District staff. ◆ Regional District staff travel to site to evaluate distribution water main failure. ◆ Bear Lake Maintenance Contractor or Regional District staff to locate and close valves to isolate the area. ◆ Regional District staff to assess the situation and make the site safe. ◆ Notify all users of the interruption of service. ◆ Arrange for repairs. ◆ Take reading of reservoir water levels from meter located in the community commission building. ◆ Advise Northern Health Authority- Public Health ◆ Arrange for an alternate water source if necessary. 	<p>See Appendix B for contact names and numbers</p> <p>RDFFG Contact</p> <p>Bear Lake Maintenance Contractor</p>
<p style="text-align: center;">Power Failure</p>	<p>See Appendix A for assigned responsibilities</p> <ul style="list-style-type: none"> ◆ Notify Regional District Staff. ◆ Call B.C. Hydro to determine the time for power restoration. ◆ Notify users to conserve water during power outage. ◆ Water supply in reservoir 2 to 2 ½ days residential use only. ◆ If the community is out of power and the mill has power and continues to operate, arrange for a generator to be brought online <u>as soon as possible</u> (see Appendix B). ◆ If both the mill and community are without power, arrange for generator if outage is estimated to be longer than 12 hours (see Appendix B). ◆ Advise Northern Health Authority- Public Health. ◆ Arrange for an alternate water source if necessary. 	<p>See Appendix “B” for contact names and numbers</p> <p>RDFFG Contact</p> <p>Bear Lake Maintenance Contractor</p> <p>B.C. Hydro</p> <p>Generator Rental</p>

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

SITUATION – TYPE OF EMERGENCY	RESPONSE	CONTACTS
<p style="text-align: center;">Complete Pump Failure at Pump House</p>	<p>See Appendix A for assigned responsibilities</p> <ul style="list-style-type: none"> ◆ Notify Regional District Staff. ◆ Secure system at pump house. ◆ Contact pump repair company. ◆ Advise Northern Health Authority- Public Health. ◆ Notify all users of interruption of service. ◆ Arrange for an alternate water source if necessary. 	<p>See Appendix B for contact names and numbers</p> <p>RDFFG Contact</p> <p>Bear Lake Maintenance Contractor</p> <p>Bear Lake Commission Member</p>
SITUATION – TYPE OF EMERGENCY	RESPONSE	CONTACTS
<p style="text-align: center;">Contamination of Water</p>	<p>See Appendix A for assigned responsibilities</p> <ul style="list-style-type: none"> ◆ Notify Regional District Staff. ◆ Notify effected users not to use water for domestic purposes, boil advisory. ◆ Advise Northern Health Authority- Public Health. ◆ If contamination occurs near the end of the water system, isolate from the rest of the system. ◆ If the entire system is contaminated drain and shut down system. ◆ Arrange for alternate water source. ◆ Bring contractor out to clear water system lines. ◆ Contact government agencies for advice and assistance. 	<p>See Appendix B for contact names and numbers</p> <p>RDFFG Contact.</p> <p>Bear Lake Maintenance Contractor</p> <p>Bear Lake Commission Member</p> <p>PEP, Ministry of Environment and others as necessary, depending on severity.</p>

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

SITUATION – TYPE OF EMERGENCY	RESPONSE	CONTACTS
<p style="text-align: center;">Fire (Forest fire in water distribution area, or firefighting with system water)</p>	<p>See Appendix A for assigned responsibilities</p> <ul style="list-style-type: none"> ◆ Notify Regional District Staff. ◆ Take reading of reservoir water levels from meter located in the community commission building. ◆ Contact government agencies for advice and assistance. ◆ Advise Northern Health Authority- Public Health. ◆ Notify all users of possible interruption of service. ◆ Arrange for an alternate water source if necessary. 	<p>See Appendix B for contact names and numbers.</p> <p>RDFFG Contact</p> <p>Bear Lake Maintenance Contractor</p> <p>Bear Lake Commission Member</p> <p>PEP, Ministry of Environment, Ministry of Forests, and others as necessary depending on severity.</p>
SITUATION – TYPE OF EMERGENCY	RESPONSE	CONTACTS
<p style="text-align: center;">Loss of Source (Water Supply)</p>	<p>See Appendix A for assigned responsibilities</p> <ul style="list-style-type: none"> ◆ Notify Regional District staff. ◆ Ensure the pump is shut off at pump house. ◆ Advise Northern Health Authority- Public Health. ◆ Notify all users of loss of service. ◆ Arrange for alternate water source. 	<p>See Appendix B for contact names and numbers.</p> <p>RDFFG Contact</p> <p>Bear Lake Maintenance Contractor</p> <p>Bear Lake Commission Member</p>

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

SITUATION – TYPE OF EMERGENCY	RESPONSE	CONTACTS
<p>Earthquake Loss or Structural Damage to Reservoir</p>	<p>See Appendix A for assigned responsibilities</p> <ul style="list-style-type: none"> ◆ Notify Regional District staff. ◆ Shut off the water lines. Close main in flow and out flow line from reservoir. ◆ Arrange for volunteers to man the pumps ◆ Manually operate water system from pump house. Cycle pumps as required to maintain adequate pressure. ◆ Advise Northern Health Authority- Public Health. ◆ Notify all users of possible interruption of service. ◆ Arrange for an alternate water source if necessary. ◆ Arrange for structural engineer to assess damage. ◆ Proceed with reservoir replacement if required. ◆ Contact government agencies (see below) for advice and assistance. 	<p>See Appendix B for contact names and numbers</p> <p>RDFFG Contact</p> <p>Bear Lake Maintenance Contractor</p> <p>Bear Lake Commission Member</p> <p>Reservoir Manufacturer</p> <p>PEP, Ministry of Environment and others as necessary depending on severity.</p>

APPENDIX A - EMERGENCY RESPONSE PLAN – RESPONSIBILITY PLAN

TITLE	ACTIONS (to take depending on emergency)
Maintenance Contractor	<ul style="list-style-type: none"> ◆ Immediately attend to emergency, assess and take appropriate action if safe to do so. ◆ Notify Regional District Emergency Contact Person and Bear Lake Commission Contact person of the nature of emergency and of the action taken (see Appendix B). ◆ Ensure the pump is shut off (to protect pump). ◆ Isolate parts or close down the entire water system. For shut-off valve location map (see Appendix F). ◆ Close both main in and out flow line from reservoir. ◆ Manually operate water system from pump house. ◆ Post appropriate signage on community notice boards e.g.: Boil advisories, contamination of water supply and conserve water (see Appendix D) ◆ Take readings of reservoir levels.
TITLE	ACTIONS (to take depending on emergency)
Designated RDFFG Staff (EOCP Certified) Contact	<ul style="list-style-type: none"> ◆ Keep in contact with Bear Lake Maintenance Contractor to assess the severity of the emergency and advise on appropriate action to take. ◆ If necessary, attend the site to advise, assist and coordinate efforts to resolve the situation. ◆ Arrange for repairs (see Appendix B). ◆ Contact Bear Lake Commission appointed member to assist with the emergency and arrange for communications within the community (see Appendix B). ◆ Contact appropriate government agencies for advice and assistance (see Appendix B).

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

	<ul style="list-style-type: none"> ◆ Notify the Northern Health Authority- Public health officer (see Appendix B). ◆ Contact media for public announcements. For media releases (see Appendix C). ◆ Post on RDFFG web site: warnings and daily status updates. ◆ Arrange for alternate source of water (see Appendix B). ◆ Contact appropriate utilities before excavating.
<p>Designated Bear Lake Community Commission Contact</p>	<ul style="list-style-type: none"> ◆ Notification of all users of water system by "Phone Tree" (see Appendix E) or "Door to door message posting" (see Appendix D). If all users of the water system <u>can't be reached</u>, contact RDFFG contact personal to issue a media release. ◆ Arrange for assistance from designated Bear Lake community members to help with emergency (man pumps etc). ◆ Take notes and photographs for documentation.

APPENDIX B - EMERGENCY RESPONSE PLAN – CONTACT LIST

RDFFG Personnel Contact Numbers

Operator's Name: Regional District of Fraser-Fort George, 155 George Street, Prince George, B.C.

Priority	Name of Contact	Phone	Location
1	Bryan Boyes, Environmental Services Utilities Leader	250-640-0049 250-960-4487	Cellular Office
2	Neil Pearson, Environmental Services Lead Hand	250-552-0951 250-960-4489	Cellular Office
3	Gina Layte Liston, Environmental Services Senior Manager	778-349-4084 250-960-4483	Cellular Office
4	RDFFG Switchboard RDFFG After Hours Emergencies	250-960-4400 250-960-4401	

Bear Lake Contact Numbers

Bear Lake: for Phone Tree see "Appendix E", for prepared signage see "Appendix D"

Priority	Name of Contact	Phone	Location
1	Ron (Ronald) Aken, Bear Lake Maintenance Contractor	250-612-7209	Cellular
2	Carolyn Aken, Relief Bear Lake Maintenance Contractor	250-613-7239	Cellular
3	Jennifer Hebert, President of BLCC	250-972-4420 250-972-4488	Residence Office
	Notification in emergency Canfor Sawmill: Erv Matzelle (Onsite Contact)	250-961-6073	Cellular
	Luke Drapeau (GM Capital & Mtce Systems)	250-640-1152	Cellular
	Petro-Canada-Service Station	250-972-4414	
	Bear Lake School	250-972-4431	
	Grizzly Inn Restaurant / Motel	250-972-4333	
	Campgrounds		

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

Emergency Contact Numbers

Government Agencies:

Agencies	Name of Contact	Phone	Location
Northern Health Authority Prince George	Medical Health Officer on-call (24/7 line, for emergencies)	1-833-214-3274	Various
Northern Health Authority Prince George	Environmental Health Officer Public Health Protection	250-565-7322	Prince George
PEP-Provincial Emergency Preparedness Program	Janelle Tuininga, Northeast Region (Dangerous Goods-Spills)	250-645-9320 1-800-663-3456	Office 24 hours
Ministry of Forests	Forest Fire Reporting	1-800-663-5555	24 hours

Emergency Contact Numbers

Public Services:

Services	Name of Contact	Phone	Location
P.G. Regional Hospital	Main Switchboard Emergency	250-565-2000 250-565-2444	24 hours
Poison Control Centre		1-800-567-8911	24 hours
Terasen Gas	Gas leaks and Odours BC One Call	1-800-663-9911 1-800-474-6886	24 hours
B.C.Hydro	Power outages Disconnection / underground service location	1-888-769-3766 1-888-520-1355	24 hours
Police		9-1-1 250-561-3300	Emergences Non-Emerg.
Bear Lake Volunteer Fire Department (not in service)		9-1-1 250-972-4377	Emergences Non-Emerg.
Ambulance		9-1-1 250-972-4424	Emergences Non-Emerg.

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

Media Contact Numbers

Public Services Announcements: See “Appendix C” for prepared public service announcements.

Media	Name of Contact	Phone	Location
Radio Station	CKPG, CKDV, CKKN, Prince George CHMM 86 Centennial, Mackenzie	250-563-0111 250-997-6277	Newsroom Office
Radio Station	CJCI	564-2524	24 hours
Radio Station	CBC	562-6701	24 hours
T.V. Station	CKPG	563-0111	Newsroom
Newspaper Prince George	The Citizen	562-2441	Office
Mackenzie Times	540 Mackenzie Blvd	997-6675	Office

Water Supply Services Contact Numbers

Bulk and Bottled Water Supply Services:

Name of Contact	Type of Problem	Phone	Location
Grandview Water Hauling 966-5 th Avenue Prince George BC V2L 3K8	Water hauler:	563-4222	Office
AquaTerra (Canadian Spring) 2385 S Nicholson Prince George BC V2N 1W1	Bottled water supplier:	1-877-442-7884	Office
Eco Pure Bottled Water 3699 Massey Dr Prince George BC V2N 4E6	Bottled water supplier:	562-7873	Office
Culligan of Prince George 521-1 st Avenue Prince George BC V2L 2Y2	Bottled water supplier:	563-4458	Office

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

Repair and Services Contact Numbers

Pump, Waterline and Reservoir Repair and Alternate Power Services:

Name of Contact	Type of Problem	Phone	Location
Fred Surridge Ltd. 2150 Robertson Road Prince George B.C. V2N 1X6	Waterworks Equipment & Supplies: Hydrants/Pipes/Fittings	250-564-4340	Office
Emco Corporation 1596 Quinn S, Prince George	Waterworks Equipment & Supplies:	250-563-1771	Office
Northlands Water & Sewer Supplies Ltd. 1733 Lyon St., Prince George	Waterworks Equipment & Supplies:	250-561-1884	Office
Andrew Sheret Ltd. 1995 Quinn st., Prince George	Waterworks Equipment & Supplies	250-561-2444	Office
West Central Fire Protection Contact: Hubert Matte 11400 Maureen Road Prince George B.C. V2N 5B7	Fire Hydrant Repair Work: Hydrant Installation / Repair Work / Cleaning Lines if contaminated	250-964-0595	Office
B K Woods & Water Supplies Ltd. 598 4 th Ave. Prince George BC V3L 3G9	Supplies and Pump Repair:	250-963-1411	Office
United Rental of Canada 2073-1 st Avenue Prince George BC V2L 2Z1	Power Outage: 45kw power plant: \$423/ day 1700kw power plant: \$5600/ day	250-564-3111	Office
PG Rental Center 1669 Lyon St S Prince George BC V2N 1T3	Power Outage: 45kw power plant: \$226/ day	250-562-2626	Office
Finning Canada 1140 Pacific Street Prince George BC V2N	Power Outage:	250-563-0331	Office
Simson-Maxwell 1846 Quinn St. Prince George	Power Outage:	250-562-2728	Office

APPENDIX C - MEDIA RELEASES – PREPARED PUBLIC SERVICE ANNOUNCEMENTS

Actions:

See Appendix “B” for contact numbers

- If all the users of the water system can't be contacted, the RDFFG designated contact person is to contact each of the listed media and issue a public service announcement.
- Let the media know that they will be contacted when the emergency is resolved.

Type of Emergency: Contamination of water source (unfit for human consumption).

To all users of the Bear Lake Drinking Water System, please be advised, the water source is unfit for human consumption and the system has been shut down until further notice. All users are urged to curtail their water use. An alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road. Another service announcement will be issued when the problem has been resolved. This has been a public service announcement from The Regional District of Fraser-Fort George.

Type of Emergency: Contamination of water source (Boil water advisory).

To all users of the Bear Lake Drinking Water System, please be advised, this is a boil water advisory. Until further notice, all users are urged to boil all water used for Human consumption. An alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road. Another service announcement will be issued when the problem has been resolved. This has been a public service announcement from The Regional District of Fraser-Fort George.

Type of Emergency: Loss of water supply (broken water main, pump failure, loss of reservoir)

To all users of the Bear Lake Drinking Water System, please be advised, the system has been shut down till further notice. All users are urged to curtail their water use. An alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road. Another service announcement will be issued when the problem has been resolved. This has been a public service announcement from The Regional District of Fraser-Fort George.

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

Type of Emergency: Limited water supply (broken water main, pump failure, loss of power, forest fire)

To all users of the Bear Lake Drinking Water System, please be advised, all users are urged to conserve water until further notice. If required, an alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road. Another service announcement will be issued when the problem has been resolved. This has been a public service announcement from The Regional District of Fraser-Fort George.

APPENDIX D - SIGNAGE – PREPARED SIGNAGE FOR POSTING

Actions:


See Appendix “B” for contact numbers


- If all the users of the water system can't be contacted, use the “Door To Door” method and go to their residence and post signage on their door stating the nature of the advisory.
- Post signs up on notice boards, and have the owners of all commercial businesses post signs where drinking water is available to non-residents (i.e. taps at a gas station, campground, sawmill or motel stating the nature of the advisory)
- Ensure all signs are removed when the problem is resolved.

NOTICE

**a conserve water
advisory is in effect**







**REGIONAL DISTRICT**
of Fraser-Fort George
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

NOTICE


**a conserve
water advisory
is in effect**



**REGIONAL DISTRICT**
of Fraser-Fort George
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

NOTICE

**a conserve
water advisory
is in effect**



**REGIONAL DISTRICT**
of Fraser-Fort George
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

NOTICE

**a conserve
water advisory
is in effect**



WARNING

**a boil water advisory
is in effect**



**REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-667-1959



**REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

WARNING

**a boil water
advisory
is in effect**



**REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

WARNING

**a boil water
advisory
is in effect**



**REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

WARNING

**a boil water
advisory
is in effect**





WARNING

**this water is considered
unfit for drinking
or domestic use**



Phone: (250) 960-4400
Toll Free: 1-800-667-1959



 REGIONAL DISTRICT
of Fraser-Fort George
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

WARNING

**this water is
considered
unfit for drinking
or domestic use**



 REGIONAL DISTRICT
of Fraser-Fort George
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

WARNING

**this water is
considered
unfit for drinking
or domestic use**



 REGIONAL DISTRICT
of Fraser-Fort George
Phone: (250) 960-4400
Toll Free: 1-800-667-1959

WARNING

**this water is
considered
unfit for drinking
or domestic use**



NOTICE

**maintenance to water system
in progress you may experience
a disruption in service**

**Date: from _____
to _____**





 **REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-687-1959

NOTICE

**maintenance to water
system in progress
you may experience
a disruption in service**

Date: from to



 **REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-687-1959

NOTICE

**maintenance to water
system in progress
you may experience
a disruption in service**

Date: from to



 **REGIONAL DISTRICT
of Fraser-Fort George**
Phone: (250) 960-4400
Toll Free: 1-800-687-1959

NOTICE

**maintenance to water
system in progress
you may experience
a disruption in service**

Date: from to

APPENDIX E - PHONE TREE – PREPARED WATER SYSTEM USER SERVICE ANNOUNCEMENTS

Actions:

See Appendix “D” for prepared signage for posting

- Phone all users of the water system starting with Canfor Sawmill, the Bear Lake School and all other commercial businesses where drinking water is available to non-residents (i.e. taps at a gas station, campground, sawmill or motel stating the nature of the advisory).
- If all the users of the water system can't be contacted see Appendix “D” and contact the RDEFG designated contact personal is to contact each of the listed media and issue a public service announcement.

Type of Emergency: Contamination of water source (unfit for human consumption).

As a user of the Bear Lake Drinking Water System please be advised, the water source is unfit for human consumption and the system has been shut down till further notice. We urged you to curtail water use to prevent contamination of your residential water pipes. An alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road at **time: _____ on date: _____**. We will contact you when the problem has been resolved and with any required actions you may have to take. Thank you for your cooperation.

Type of Emergency: Contamination of water source (Boil water advisory).

As a users of the Bear Lake Drinking Water System, please be advised, this is a boil water advisory. Until further notice, all users are urged to boil all water used for Human consumption. An alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road at **time: _____ on date: _____**. We will contact you when the problem has been resolved and with any required actions you may have to take. Thank you for your cooperation.

Type of Emergency: Loss of water supply (broken water main, pump failure, loss of reservoir)

As a user of the Bear Lake Drinking Water System, please be advised the system has been shut down till further notice. We urged all users to curtail their water use to prevent complete drainage of the system. An alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road at **time: _____ on date: _____**. We will contact you when the problem has been resolved and with any required actions you may have to take. Thank you for your cooperation.

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

Type of Emergency: Limited water supply (broken water main, pump failure, loss of power, forest fire)

As a user of the Bear Lake Drinking Water System, please be advised, we urge you to conserve water until further notice to prevent complete drainage of the system. If required, an alternate source of drinking water will be provided for pick-up at the Bear Lake Community Commission Office at 353 Grizzly Road at **time:** **on date:**. We will contact you when the problem has been resolved and with any required actions you may have to take. Thank you for your cooperation.

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

PHONE TREE – LIST OF BEAR LAKE WATER SYSTEM USERS TO CONTACT

Bear Lake Contact Numbers

Bear Lake: for prepared signage see Appendix “D”

Name of Contact	Address	Phone	Location	Contacted Yes/No Left Mes.
B				
Bear Lake VFD / BLCC Office	353 Grizzly	972-4488	Non-emrg	
Boreland E & C Perron	475 Cinnamon	972-4343	Res.	
C				
Callaghan Don	328 Grizzly	972-4414	Office	
Canfor: Polar, Erv	36654 Hart Hwy	250-961-6073	Cell	
Charest Richard & June	487 Grizzly	972-4358	Res.	
Chenail Peter	472 Cinnamon	972-4482	Res.	
Chingee Adele	408 Cub	972-4292	Res.	
Colquhoun Graham, Lloyd & Janice	222 Industrial Way	972-4403	Res.	
Cunningham Vernon	490 Panda St	972-4265	Res.	
D				
D & E Callaghan Ltd.	328 Grizzly	972-4414		
Danroth Don & Vicky	583 Kodiak	972-4366	Res.	
Danroth Greg & Denise	412 Grizzly	972-4413	Res.	
Danroth Russell & Georgina	557 Kodiak	972-4392	Res.	
Delvenne Aime & Mayo	427 Hart Lk	972-4447	Res.	
Delvenne Phillip	348 Polar	972-4410	Res.	
Djuric Ratko	477 Panda St.	972-4479	Res.	
E				
Elmquist Donald	445 Hart Lk Rd	972-4453	Res.	
Evert Robert	443 Cinnamon	972-4495	Res.	
F				
Falkowaky Brent	300 Industrial Way	972-4407	Res.	
Falkowaky Cliff	515 Polar	972-4448	Res.	
Falkowaky Enterprises Ltd	515 Polar	972-4396		
Fuson O.	485 Polar	972-4385	Res.	
G				
Gagne Robert	310 Cinnamon	972-4443	Res.	
Gallant Ivan	488 Cinnamon	972-4360	Res.	
Gammon Wayne & Angie	490 Kodiak	972-4322	Res.	
Giesbrecht B	442 Koala Pl	972-4319	Res.	
Giesbrecht Herbert	429 Koala pl.	972-4311	Res.	
Grattan Greg & Patty	550 Kodiak St	972-4468	Res.	
Green Graham & Betty	540 Kodiak	972-4375	Res.	
Grizzly Inn Restaurant	36530 Hart Hwy	972-4333		

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

Gronning Edward & Everta	448 Kodiak	972-4352	Res.	
H				
Hagen Curtis	545 Kodiak	972-4314	Res.	
Hagen Stan	560 Polar	972-4441	Res.	
Haight Caroline	417 Kodiak	972-4428	Res.	
Haight Robert & Sharon	583 Polar	972-4337	Res.	
Hawryliw Ervin & Angeline	593 Kodiak	972-4387	Res.	
Herbert Gerard	447 Koala Pl	972-4445	Res.	
Hill Rose M.		972-4405	Res.	
Himmelspach Joe	522 Panda	972-4382	Res.	
I				
Isadore Eugene & Doreen	510 Kodiak	972-4363	Res.	
Isadore Genia / Arthurs Darcy	350 Cinnamon	972-4491	Res.	
J				
Jantz Larry	533 Polar	972-4299	Res.	
John Elmquest & Son Trucking	260 Industrial Way	972-4455		
L				
Lloyd Colquhoun Contracting	222 Industrial Way	972-4464		
M				
Macfadzen Roy	449 Polar	972-4418	Res.	
Marshall Ed	595 Polar	972-4334	Res.	
Mazzei Ron & Josie Collins	450 Cinnamon	972-4446	Res.	
McCartney Cecil	466 Kodiak	972-6806	Res.	
McFadzen B.	569 Kodiak St	972-4378	Res.	
McGee Patrick & Janet (Bear Lake Maint. Contractor)	470 Polar	972- 4294 972-4296	Res.	
Meyer John	464 Panda	972-4466	Res.	
Michaud's Contracting	180 Industrial Way	972-4438		
Miller David	422 Koala Pl	972-400	Res.	
N				
Nilsen Barry	580 Kodiak	972-4477	Res.	
P				
Pas Lumber Co Ltd.	35178 hart Hwy	972-4476		
Patterson D.& B.	430 Polar	972-4456	Res.	
Pattison D	429 Polar	972-4422		
Petro-Canada Service	328 Grizzly	972-4414	Station	
S				
Scharfenberg David	365 Polar	972-4365	Res.	
Schellenberg Micheline	874 Hart Lk	972-4467	Res.	
Schofeild J. E.	565 Polar	972-4388	Res.	
Schofield Lisa & Allan	358 Polar	972-4298	Res.	
Sculthorp E.F.	376 Cinnamon	972-4417		
T				
Tardif Paul	410 Cub	972-4399	Res.	

Emergency Response and Contingency Plan for The
Bear Lake Small Waterworks System

V				
Van Bruggen H.	390 Hart Lk	972-4398	Res.	
W				
Wagman Shannon	436 Grizzly	972-4452		
Waldner Bruce	586 Polar	972-4347		
Wall C.	465 Polar	972-4490	Res.	
Warland Harvey & Barb	620 Kodiak	972-4498	Res.	
Wilson D & B	375 Polar	972-4498	Res.	
Wynnychuk Fred	432 Cinnamon	972-4473	Res.	
Y				
Yellowhead Road & Bridge	Hart Hwy	972-4373		
Unlisted				

Emergency Response and Contingency Plan for The Bear Lake Small Waterworks System

APPENDIX F - WATER SYSTEM DRAWING

