



August 21, 2023

ADDENDUM No. 2

**Invitation to Quote CS-23-04
STRUCTURE FIRE FIGHTING HOSE**

*The addendum is being issued prior to the closing of the Invitation to Quote (ITQ) to provide further information, make changes to, or to clarify the ITQ Documents and is to be read, interpreted, and coordinated with all other parts of the ITQ Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall attach a signed copy of this addendum to their bid submission, failure to do so may result in a non-compliant bid.** This addendum shall form part of the Contract Documents.*

This addendum is being provided in clarification to ITQ CS-23-04 released July 26, 2023.

Question 1: What pressures will be used during deployment of the hoses and what type of nozzles are typically used?

Answer 1: Hose will need to have service pressure test rating of 400 psi. Standard structural hand grip nozzles are generally used.

Question 2: What couplings are needed on each of the hose sizes? (1.5" – NPSH Thread, 2.5" BCT Thread)

Answer 2: The 1.5" and 1.75" hose will require 1.5" NPSH Thread and the 2.5" will require 2.5" BAT Thread.

Question 3: Is there a component in this Bid that deals with performance and an expectation for product guarantees?

Answer 3: All hose performance requirement needs to meet NFPA Standard 1962. Bidders can provide vendor warranty for hose.

I/We hereby verify that we have considered this addendum in our proposal submission.

Proponent's Signature

Date

All inquiries relating to ITQ CS-23-04 must be emailed to:
Bonnie Seitz, Community Services Leader, bseitz@rdffg.bc.ca