



May 26, 2025

CS-25-04- NUKKO LAKE WATER TREATMENT SYSTEM SITE MEETING NOTES

These site meeting notes form part of the Tender Documents and shall be read, interpreted, and coordinated with all other parts. The cost of all the work contained herein, if applicable, shall be included in the Tender submission. The following revisions, changes, corrections, additions, and or deletions supersede the information contained in the original Documents to the extent referenced and shall become part thereof.

A site meeting regarding Invitation to Tender CS-25-04 Nukko Lake Water Treatment System, was held on May 21, 2025. The following captures the relevant points of the meeting:

- All tenderers who intend to submit a bid for this project should complete and sign appendix 7 “acknowledgement letter” and email the signed acknowledgment letter to Cindy Paton, Manager of Community Services, at cpaton@rdffg.bc.ca.
- Addendum #1 was released on May 7, 2025, reflecting the adjusted dates relevant to this ITT. Bidders must sign the addendum and include it with their bid submission.
- The last day for questions regarding this ITT is May 28, 2025, at 16:00 PDT.
- The closing date of this ITT is June 10, 2025, at 14:00 PDT.

McElhanney representative, Ethan Hoffman provided a tour of the worksite at Nukko Lake Community Hall. Equipment that will be retained includes the well pump, pressure tank and hot water tank.

Key piece to note in the design is that the UV lamp installation requires the lamp to be removed from the top and this will require modification of the pressure tank platform. The electric panel will require the addition of 1 more circuit.

There were no questions from the site visit attendees,

Meeting adjourned at 13:30 PDT.