



---

March 5, 2026

**ADDENDUM No. 4**

**REQUEST FOR PROPOSAL PS-26-01 PINEVIEW FRONTLINE WATER TENDER,**

*The addendum is being issued prior to the closing of the Request for Proposal (RFP) to provide further information, make changes to, or to clarify the RFP Documents and is to be read, interpreted and coordinated with all other parts of the RFP Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Proponents shall attach a signed copy of this addendum to their proposal submission, failure to do so may result in a non-compliant proposal.** This addendum shall form part of the Contract Documents.*

---

Question 1 is being provided in clarification to RFP PS-26-01 released January 23, 2026.

Question 1: PS-26-01 Pineview Frontline Water Tender. Appendix "E" Minimum Specification Pumping and Controls Item 10. states "3" tank fill, with electric valve – location to be determined at preconstruction meeting." Can you please clarify if this is to be a pump to tank valve or a direct tank fill.

**Answer 1: The "3" tank fill, with electric valve will be a pump to tank valve.**

I/We hereby verify that we have considered this addendum in our proposal submission.

\_\_\_\_\_  
Proponent's Signature

\_\_\_\_\_  
Date

All inquiries relating to RFP PS-26-01 must be emailed to:  
Bonnie Seitz, Community Services Leader, [bseitz@rdffg.bc.ca](mailto:bseitz@rdffg.bc.ca)